

# IMPORTANT

Inspection & testing has been undertaken by the following entity accredited for this work:

YOUR LOGO,  
CONTACT DETAILS,  
CPS NUMBER AND  
CPS LOGO HERE  
MOFOs!

**THIS INSTALLATION SHOULD BE PERIODICALLY INSPECTED AND TESTED AND A REPORT ON ITS CONDITION OBTAINED, AS PRESCRIBED IN THE IET WIRING REGULATIONS BS7671 REQUIREMENTS FOR ELECTRICAL INSTALLATIONS.**

DATE OF INSPECTION:	SCOPE OF INSPECTION:	CONDITION OF INSTALLATION:	Verify at: <a href="http://electricalcompetentperson.co.uk">electricalcompetentperson.co.uk</a>
REPORT/CERTIFICATE REFERENCE:	<i>Replacement CU/DB</i>	<b>SATISFACTORY</b> <i>Safe for continued use*</i> <b>INITIAL:</b>	*Refer to report for extent & limitations.  **It is the duty holder's responsibility to ensure resolution of any safety issues as identified without delay.
	<i>Partial/Full Rewire</i>		
NEXT INSPECTION RECOMMENDED:  <i>This date is invalid in the event of damage/deterioration.</i>	<i>Condition report</i>	<b>UNSATISFACTORY</b> <i>Remedial action is now required**</i> <b>INITIAL:</b>	Next inspection date applies only where any remedial action identified has been satisfactorily undertaken and certified.
	<i>New / additions &amp; alterations:</i>		

Legacy installations may contain wiring colours to two versions of BS7671. Great care should be taken when undertaking extension, alteration or repair that all conductors are correctly identified.